



Farm fence gate

1:20

- 6. All posts to be approved FSC or recycled hardwood.
- 7. Timber treatment shall comply with the current requirements of the timber preservation council. All timber shall be branded with the appropriate woodmark. It is preferred that timber be treated 2 months prior to use.
- 8. All sharp edges are to be smoothed slightly to avoid splinters.
- 9. Post tops should be angled and chamfered.
- 10. Timber posts to be spaced no more than 2m apart, for post locations refer Arrangement Plans (L8101-2).
- 11. Nails:
 - General structural use 100x4mm FH.
 - All nails shall be hot dipped galvanised.
- 12. All concrete to have a minimum strength of 20MPa.
- 13. Ensure that concrete does not dry out during curing period.
- 14. Ensure all disturbed areas of grass are hydroseeded upon completion of installation.

These drawings are not suitable for construction and are provided for guidance only. They should be reviewed by a suitably qualified engineer or landscape architect and modified to meet site-specific requirements.



PROJECT:				
0:	Information	PCF	PCF	4/11/2025
REV	DESCRIPTION	BY	CHKD	DATE

PROJECT NAME:			
PCF STANDARD DETAILS-Fencing & Gate			
ISSUED FOR:			
Information			
Sheet Title:	FARM FENCE GATE		
Project No:	Scale:	Sheet Number:	Revision:
	1:20	PCF006	0